



MINISTERUL SANATATII  
DIRECTIA DE SANATATE PUBLICA-TELEORMAN  
Laborator de diagnostic si investigare in sanatate publica  
Alexandria str. Mihaita Filipescu nr, 30, tel: 0247311482,Fax:0247312095

**BULETIN ANALIZE MICROBIOLOGICE –APA**  
**Nr. 465 din : ziua 11 luna 05 anul 2020**

SOLICITANT/BENEFICIAR:SC. APA SERV SA –ALEXANDRIA

ADRESA:ALEXANDRIA - JUD. TELEORMAN

Tipul probei : Apa potabila

Locul prelevarii: Proba apa statie tratare Laceni; Proba apa statie tratare PECO ; Proba apa Spital Judetean; Proba apa statie Epurare

Cine preleveaza/data si ora prelevarii:Clapan A. /27/04/2020/ora 10,00

Cantitatea prelevata/document prelevare:4x500ml/P.V.96 / monitorizare operationala

Cine primeste/data si ora primirii:As. Popa M./27/04/2020/ora 12,00

Starea probei la receptie : corespunzatoare ; Data efectuarii analizei :27-30.04.2020

Observatii:

Rezultatele se refera numai la probele analizate.

Reproducerea partiala/totala a buletinului de rezultate este interzisa.

Buletinul de analiza se emite in 2 exemplare:exemplarul 1 la beneficiar;exemplarul 2 la laborator.

Valorile maxime admise(VMA) sunt conforme cu prevederile legii 458/2002privind calitatea apei potabile, republicata in/2012.

Analizele marcate cu \* nu sunt acreditate RENAR.

Exemplar nr.2

Pag.1 din 2

Nr. Reg. unic	SURSA DE APA	Nr.col. la 37°C/1ml SR EN ISO 6222/2004		Nr.col. la 22°C/1ml SR EN ISO 6222/2004		Nr. total bacterii coliforme/100ml SR EN ISO 9308-1/2015/A1/2017		Escherichia coli/100ml SR EN ISO 9308-1/2015/A1/2017		Enterococi intestinali/100ml SR EN ISO 7899/2002		*Pseudomonas aeruginosa/100ml SR EN ISO 16266/2008		Clostridium perfringens/100ml/ PST-M-13	
		VMMA/nicio modificare anormala	Val. determ.	VMMA/nicio modificare anormala	Val. determ.	VMMA 0	Val. determ.	VMMA 0	Val. determ.	VMMA 0	Val. determ.	VMMA 0	Val. determ.	VMMA 0	Val. determ.
618	Proba apa stative tratate Laceni	0		0		0		0		0		-		-	
619	Proba apa stative tratate PECO	0		0		0		0		0		-		-	
620	Proba apa Spital Judetean	0		0		0		0		0		-		-	
621	Proba apa stative Epurare	0		0		0		0		0		-		-	

Abrevieri

ufc = unitati formatoare de colonii  
VMA = valoare maxima admisa

COORDONATOR LABORATOR,  
**UDORICA CRISTIANA**  
 medic veterinar  
 microbiologie medicala  
 Col. 098223

RESPONSABIL AMPLICA,  
**LIANA IONESCU**  
 JIA Biologie  
 Col. 098223