



S.C. APA SERV S.A.

Str. Vedeia, Nr. 31, Alexandria, Jud. Teleorman, Cod Postal 140052
Tel: 0247 / 311.272; Fax: 0247 / 313.218; e-mail: apaserv.alex@yahoo.com
ORC: J34/529/2007; CUI: RO22224874; birtehnic@yahoo.com
Cont: RO88 RNCB 0245 0890 9243 0001; Banca: BCR, sucursala Alexandria



Sucursala Alexandria

Lab. Calitatea Apei

Cerificat de inregistrare
M.S. nr. 576 /15.07.2020

Avizat: Director tehnic,

Ing. Theodor COSMA

BULETIN DE ANALIZA

Cu rezultatul determinarilor chimice efectuate pe probele de apa potabila in ziua de 11 luna 05 anul 2022

Nr. crt.	Punct de recoltare	PH (unit. pH)	NH ₄ ⁺ (mg/l)	NO ₂ ⁻ (mg/l)	NO ₃ ⁻ (mg/l)	Cloruri (mg/l)	Oxidabilitate (mg O ₂ / l)	Clor rezid. (mg/l)	Turbiditate (ntu)	D ⁰ (gr.ger mane)	Conductivitate electrica (µS/cm)	Fe total (mg/l)	Mn ²⁺ mg/l	Clor legat (mg/l)	Clor total (mg/l)
	Limite Maxime Admise conform legii 458/2002 republicată	6,5-9,5 unitati de pH	0,5 mg/l	0,5 mg/l	35-50 mg/l	250 mg/l	5,0 mg O ₂ /l	0,5-0,1 mg/l	5,0 NTU	Min. 5 gr.ger mane	2500 (µS/cm)	0,2 mg/l	0,05 mg/l	-	1,0 mg/l
676	Iesire Bazin	7,9/ 20,0°C	5,71	0,032	2,67	28,4	3,3	0,5	2,42	3,5	-	-	-	0,6	1,1
678	St.Deferizare	7,5/ 20,0°C	2,29	0,023	5,66	15,9	1,1	0,5	1,35	11,8	-	-	-	0,5	1,0
679	Vedeia-31	7,8/ 20,0°C	5,62	0,092	2,52	26,6	2,5	0,45	2,21	3,5	-	-	-	0,55	1,0
680	Piata Centrala	7,8/ 20,0°C	5,39	0,125	2,61	28,4	2,7	0,4	1,81	3,5	-	-	-	0,4	0,8

Intocmit,
Sef D.M.C.A.,
Chimist Georgescu Iuliana