



S.C. APA SERV S.A.

Str. Vedeia, Nr. 31, Alexandria, Jud. Teleorman, Cod Postal 140052  
Tel: 0247 / 311.272; Fax: 0247 / 313.218; e-mail: apaserv.alex@yahoo.com  
ORC: J34/529/2007; CUI: RO22224874;  
Cont: RO88 RNCB 0245 0890 9243 0001; Banca: BCR, sucursala Alexandria



Sucursala Alexandria

Lab. Calitatea Apei

Cerificat de inregistrare  
M.S. nr. 576 /15.07.2020

Avizat: Director tehnic,

Ing. Theodor COSMA

### BULETIN DE ANALIZA

Cu rezultatul determinarilor chimice efectuate pe probele de apa potabila in ziua de 14 luna 03 anul 2022

Nr. crt.	Punct de recoltare	PH (unit. pH)	NH4+ (mg/l)	NO2- (mg/l)	NO3- (mg/l)	Cloruri (mg/l)	Oxidabilitate (mg O <sub>2</sub> / l)	Clor rezid. (mg/l)	Turbiditate (ntu)	D <sup>0</sup> (gr.ger mane)	Conductivitate electrica (µS/cm)	Fe total (mg/l)	Mn <sup>2+</sup> mg/l	Clor legat (mg/l)	Clor total (mg/l)
	Limite Maxime Admise conform legii 458/2002 republicată	6,5-9,5 unitati de pH	0,5 mg/l	0,5 mg/l	35-50 mg/l	250 mg/l	5,0 mg O <sub>2</sub> /l	0,5-0,1 mg/l	5,0 NTU	Min. 5 gr.ger mane	2500 (µS/cm)	0,2 mg/l	0,05 mg/l	-	1,0 mg/l
353	Iesire Bazin	8,0/ 20,0°C	5,80	0,039	2,65	26,6	4,1	0,5	1,58	4,0	-	0,188	0,047	0,6	1,1
355	St.Deferizare	7,8/ 20,0°C	1,81	0,029	5,97	17,7	1,5	0,5	2,04	12,5	-	0,198	0,082	0,5	1,0

Intocmit,  
Sef D.M.C.A.,  
Chimist Georgescu Iuliana