



S.C. APA SERV S.A.

Str. Vedea, Nr. 31, Alexandria, Jud. Teleorman, Cod Postal 140052  
Tel: 0247 / 311.272; Fax: 0247 / 313.218; e-mail: apaserv.alex@yahoo.com  
ORC: J34/529/2007; CUI: RO22224874; birtehnic@yahoo.com  
Cont: RO88 RNCB 0245 0890 9243 0001; Banca: BCR, sucursala Alexandria



Sucursala Alexandria

Lab. Calitatea Apei

Avizat: Director tehnic,

Ing. Theodor COSMA

Cerificat de inregistrare

M.S. nr. 576 /15.07.2020

### BULETIN DE ANALIZA

Cu rezultatul determinarilor chimice efectuate pe probele de apa potabila in ziua de 09 luna 05 anul 2022

Nr.crt	Punct de recoltare	PH (unit. pH)	+ NH <sub>4</sub> (mg/l)	- NO <sub>2</sub> (mg/l)	- NO <sub>3</sub> (mg/l)	Cloruri (mg/l)	Oxidabilitate (mg O <sub>2</sub> / l)	Clor rezid. (mg/l)	Turbiditate (ntu)	D <sup>0</sup> (gr.germane)	Conductivitate electrica (μS/cm)	Fe total (mg/l)	Mn mg/l	Clor legat (mg/l)	Clor total (mg/l)
	Limite Maxime Admise conform legii 458/2002 republicată	6,5-9,5 unitati de pH	0,5 mg/l	0,5 mg/l	35-50 mg/l	250 mg/l	5,0 mg O <sub>2</sub> /l	0,5-0,1 mg/l	5,0 NTU	Min. 5 gr.germane	2500 μS/cm	0,2 mg/l	0,05 mg/l	-	1,0 mg/l
660	St. Tratare Rosiorii de Vede	7,5/ 20,0°C	0,45	<0,004	2,27	21,3	1,4	0,35	3,89	26,8	789/ 20,0°C	0,189	0,045	0,15	0,5
661	Piata Rosiorii de Vede	7,5/ 20,0°C	0,15	0,049	2,19	19,5	1,4	0,15	2,31	26,4	804/ 20,0°C	0,175	0,049	0,15	0,3
662	SC Urbis SA Rosiorii de Vede	7,5/ 20,0°C	0,09	0,042	2,25	19,5	0,6	0,1	3,57	25,9	822/ 20,0°C	0,190	0,045	0,05	0,15

Intocmit,  
Sef D.M.C.A.,  
Chimist Georgescu Iuliana