



S. C. A P A S E R V S. A.

Str. Vedea, Nr. 31, Alexandria, Jud. Teleorman, Cod Postal 140052
Tel: 0247 / 311.272; Fax: 0247 / 313.218; e-mail: apaserv.alex@yahoo.com
ORC: J34/529/2007; CUI: RO22224874; birtehnic@yahoo.com
Cont: RO88 RNCB 0245 0890 9243 0001; Banca: BCR, sucursala Alexandria



Sucursala Alexandria
Lab. Calitatea Apei

Avizat: Director tehnic,
Ing. Theodor COSMA

Cerificat de inregistrare
M.S. nr. 576 /15.07.2020

BULETIN DE ANALIZA

Cu rezultatul determinarilor chimice efectuate pe probele de apa potabila in ziua de 27 luna 01 anul 2022

Nr.crt	Punct de recoltare	pH (unit. pH)	NH ⁺ (mg/l)	NO ₂ ⁻ (mg/l)	NO ₃ ⁻ (mg/l)	Cloruri (mg/l)	Oxidabilitate (mg O ₂ /l)	Clor rezid. (mg/l)	Turbiditate (ntu)	D ⁰ (gr.germa ne)	Conducti vitate electrica (μS/cm)	Fe total (mg/l)	Mn ²⁺ mg/l	Clor legat (mg/l)	Clor total (mg/l)
	Limite Maxime Admise conform legii 458/2002 republicată	6,5-9,5 unitati de pH	0,5 mg/l	0,5 mg/l	35-50 mg/l	250 mg/l	5,0 mg O ₂ /l	0,5- 0,1 mg/l	5,0 NTU	Min. 5 gr.germa ne	2500 μS/cm	0,2 mg/l	0,05 mg/l	-	1,0 mg/l
124	St. Tratare Turnu Magurele	7,7/ 20,0°C	0,09	<0,004	1,99	88,7	3,5	0,5	4,88	13,2	527/ 20,0°C	-	-	0,1	0,6
125	Piata Turnu Magurele	7,7/ 20,0°C	0,05	<0,004	3,65	94,0	2,6	0,35	4,62	13,6	531/ 20,0°C	-	-	0,05	0,4

Intocmit,
Sef D.M.C.A.,
Chimist Georgescu Iuliana