



S.C. APA SERV S.A.

Str. Vedea, Nr. 31, Alexandria, Jud. Teleorman, Cod Postal 140052  
Tel: 0247 / 311.272; Fax: 0247 / 313.218; e-mail: apaserv.alex@yahoo.com  
ORC: J34/529/2007; CUI: RO22224874;  
Cont: RO88 RNCB 0245 0890 9243 0001; Banca: BCR, sucursala Alexandria



Sucursala Alexandria  
Lab. Calitatea Apei

Avizat: Director tehnic,  
Ing. Theodor COSMA

Cerificat de inregistrare  
M.S. nr. 576 /15.07.2020

### BULETIN DE ANALIZA

Cu rezultatul determinarilor chimice efectuate pe probele de apa potabila in ziua de 09 luna 05 anul 2022

Nr.crt	Punct de recoltare	pH (unit. pH)	NH <sup>+</sup> (mg/l)	NO <sub>2</sub> <sup>-</sup> (mg/l)	NO <sub>3</sub> <sup>-</sup> (mg/l)	Cloruri (mg/l)	Oxidabilitate (mg O <sub>2</sub> /l)	Clor rezid. (mg/l)	Turbiditate (ntu)	D <sup>0</sup> (gr.germa ne)	Conducti vitate electrica (μS/cm)	Fe total (mg/l)	Mn <sup>2+</sup> mg/l	Clor legat (mg/l)	Clor total (mg/l)
	Limite Maxime Admise conform legii 458/2002 republicată	6,5-9,5 unitati de pH	0,5 mg/l	0,5 mg/l	35-50 mg/l	250 mg/l	5,0 mg O <sub>2</sub> /l	0,5- 0,1 mg/l	5,0 NTU	Min. 5 gr.germa ne	2500 μS/cm	0,2 mg/l	0,05 mg/l	-	1,0 mg/l
663	St. Tratare Turnu Magurele	7,6/ 20,0°C	<0,033	<0,004	2,38	83,4	1,4	0,5	4,96	13,4	593/ 20,0°C	0,178	0,040	0,3	0,8
664	Piata Turnu Magurele	7,6/ 20,0°C	<0,033	<0,004	2,52	86,9	1,4	0,4	4,48	14,3	659/ 20,0°C	0,185	0,045	0,3	0,7

Intocmit,  
Sef D.M.C.A.,  
Chimist Georgescu Iuliana