



S.C. APA SERV S.A.

Str. Vedea, Nr. 31, Alexandria, Jud. Teleorman, Cod Postal 140052
Tel: 0247 / 311.272; Fax: 0247 / 313.218; e-mail: apaserv.alex@yahoo.com
ORC: J34/529/2007; CUI: RO22224874; birtehnic@yahoo.com
Cont: RO88 RNCB 0245 0890 9243 0001; Banca: BCR, sucursala Alexandria



Sucursala Alexandria

Lab. Calitatea Apei

Cerificat de inregistrare

M.S. nr. 576 /15.07.2020

Avizat: Director tehnic,

Ing. Theodor COSMA

BULETIN DE ANALIZA

Cu rezultatul determinarilor chimice efectuate pe probele de apa potabila in ziua de 12 luna 04 anul 2022

Nr. crt.	Punct de recoltare	PH (unit. pH)	NH ₄ ⁺ (mg/l)	NO ₂ ⁻ (mg/l)	NO ₃ ⁻ (mg/l)	Cloruri (mg/l)	Oxidabilitate (mg O ₂ /l)	Clor rezid. (mg/l)	Turbiditate (ntu)	D ⁰ (gr.germane)	Conductivitate electrica	Fe total (mg/l)	Mn ²⁺ mg/l	Clor legat (mg/l)	Clor total (mg/l)
	Limite Maxime Admise conform legii 458/2002 republicată	6,5-9,5 unitati de pH	0,5 mg/l	0,5 mg/l	35-50 mg/l	250 mg/l	5,0 mg O ₂ /l	0,5-0,1 mg/l	5,0 NTU	Min. 5 gr.germane	2500 (µS/cm)	0,2 mg/l	0,05 mg/l	-	1,0 mg/l
524	St. Tratare Videle	7,7/ 20,0°C	0,92	<0,004	1,43	15,9	0,6	0,5	1,88	13,2	595/ 20,0°C	0,165	0,040	0,5	1,0
525	Piata Videle	7,7/ 20,0°C	0,94	<0,004	1,88	15,9	0,7	0,4	1,71	11,4	482/ 20,0°C	0,182	0,048	0,5	0,9
526	Policlinica Videle	7,8/ 20,0°C	0,86	<0,004	1,63	14,2	0,6	0,45	0,98	12,5	493/ 20,0°C	0,177	0,045	0,35	0,8

Intocmit,
Sef D.M.C.A.,
Chimist Georgescu Iuliana