



S.C. APA SERV S.A.

Str. Vedea, Nr. 31, Alexandria, Jud. Teleorman, Cod Postal 140052  
Tel: 0247 / 311.272; Fax: 0247 / 313.218; e-mail: apaserv.alex@yahoo.com  
ORC: J34/529/2007; CUI: RO22224874; birtehnic@yahoo.com  
Cont: RO88 RNCB 0245 0890 9243 0001; Banca: BCR, sucursala Alexandria



Sucursala Alexandria

Lab. Calitatea Apei

Cerificat de inregistrare

M.S. nr. 576 /15.07.2020

Avizat: Director tehnic,

Ing. Theodor COSMA

### BULETIN DE ANALIZA

Cu rezultatul determinarilor chimice efectuate pe probele de apa potabila in ziua de 19 luna 05 anul 2022

Nr. crt.	Punct de recoltare	PH (unit. pH)	NH <sub>4</sub> <sup>+</sup> (mg/l)	NO <sub>2</sub> <sup>-</sup> (mg/l)	NO <sub>3</sub> <sup>-</sup> (mg/l)	Cloruri (mg/l)	Oxidabilitate (mg O <sub>2</sub> /l)	Clor rezid. (mg/l)	Turbiditate (ntu)	D <sup>0</sup> (gr.germane)	Conductivitate electrica	Fe total (mg/l)	Mn <sup>2+</sup> mg/l	Clor legat (mg/l)	Clor total (mg/l)
	Limite Maxime Admise conform legii 458/2002 republicată	6,5-9,5 unitati de pH	0,5 mg/l	0,5 mg/l	35-50 mg/l	250 mg/l	5,0 mg O <sub>2</sub> /l	0,5-0,1 mg/l	5,0 NTU	Min. 5 gr.germane	2500 (µS/cm)	0,2 mg/l	0,05 mg/l	-	1,0 mg/l
729	St. Tratare Videle	7,6/ 20,0°C	1,19	<0,004	2,23	12,4	1,5	0,5	1,61	10,9	586/ 20,0°C	0,195	0,048	0,5	1,0
730	Piata Videle	7,7/ 20,0°C	1,25	<0,004	2,12	10,6	1,5	0,45	2,75	9,6	557/ 20,0°C	0,176	0,045	0,45	0,9
731	Policlinica Videle	7,7/ 20,0°C	1,11	<0,004	2,01	12,4	0,7	0,4	1,94	10,0	409/ 20,0°C	0,181	0,045	0,4	0,8

Intocmit,  
Sef D.M.C.A.,  
Chimist Georgescu Iuliana