



S.C. APA SERV S.A.

Str. Vedea, Nr. 31, Alexandria, Jud. Teleorman, Cod Postal 140052  
Tel: 0247 / 311.272; Fax: 0247 / 313.218; e-mail: apaserv.alex@yahoo.com  
ORC: J34/529/2007; CUI: RO22224874; birtehnic@yahoo.com  
Cont: RO88 RNCB 0245 0890 9243 0001; Banca: BCR, sucursala Alexandria



Sucursala Alexandria

Lab. Calitatea Apei

Cerificat de inregistrare  
M.S. nr. 576 /15.07.2020

Avizat: Director tehnic,  
Ing. Theodor COSMA

### BULETIN DE ANALIZA

Cu rezultatul determinarilor chimice efectuate pe probele de apa potabila in ziua de 05 luna 04 anul 2022

Nr.crt	Punct de recoltare	PH (unit. pH)	+ NH <sub>4</sub> (mg/l)	- NO <sub>2</sub> (mg/l)	- NO <sub>3</sub> (mg/l)	Cloruri (mg/l)	Oxidabilitate (mg O / l) 2	Clor rezid. (mg/l)	Turbiditate (ntu)	D <sup>0</sup> (gr.germane)	Conductivitate electrica (μS/cm)	Fe total (mg/l)	Mn mg/l	Clor legat (mg/l)	Clor total (mg/l)
	Limite Maxime Admise conform legii 458/2002 republicată	6,5-9,5 unitati de pH	0,5 mg/l	0,5 mg/l	35-50 mg/l	250 mg/l	5,0 mg O <sub>2</sub> /l	0,5- 0,1 mg/l	5,0 NTU	Min. 5 gr.germane	2500 μS/cm	0,2 mg/l	0,05 mg/l	-	1,0 mg/l
476	St. Tratare Zimnicea	7,5/ 20,0°C	<0,033	<0,004	44,6	266,2	2,1	0,5	0,94	28,4	1966/20,0°C	0,116	0,026	0,05	0,55
477	Piata Zimnicea	7,4/ 20,0°C	<0,033	<0,004	47,3	262,7	1,9	0,3	1,04	28,0	1903/20,0°C	0,131	0,030	0,05	0,35
478	Sediul Apa Serv Zimnicea	7,4/ 20,0°C	<0,033	<0,004	46,0	262,7	1,0	0,35	1,35	28,4	1960/20,0°C	0,122	0,030	0,05	0,4

Intocmit,  
Sef D.M.C.A.,  
Chimist Georgescu Iuliana