



S.C. APA SERV S.A.

Str. Vedea, Nr. 31, Alexandria, Jud. Teleorman, Cod Postal 140052
Tel: 0247 / 311.272; Fax: 0247 / 313.218; e-mail: apaserv.alex@yahoo.com
ORC: J34/529/2007; CUI: RO22224874; birtehnic@yahoo.com
Cont: RO88 RNCB 0245 0890 9243 0001; Banca: BCR, sucursala Alexandria



Sucursala Alexandria

Lab. Calitatea Apei

Avizat: Director tehnic,

Ing. Theodor COSMA

Cerificat de inregistrare

M.S. nr. 576 /15.07.2020

BULETIN DE ANALIZA

Cu rezultatul determinarilor chimice efectuate pe probele de apa potabila in ziua de 08 luna 02 anul 2022

Nr.crt	Punct de recoltare	PH (unit. pH)	+ NH ₄ (mg/l)	- NO ₂ (mg/l)	- NO ₃ (mg/l)	Cloruri (mg/l)	Oxidabilitate (mg O / l) 2	Clor rezid. (mg/l)	Turbiditate (ntu)	D ⁰ (gr.germane)	Conductivitate electrica (μS/cm)	Fe total (mg/l)	Mn mg/l	Clor legat (mg/l)	Clor total (mg/l)
	Limite Maxime Admise conform legii 458/2002 republicată	6,5-9,5 unitati de pH	0,5 mg/l	0,5 mg/l	35-50 mg/l	250 mg/l	5,0 mg O ₂ /l	0,5- 0,1 mg/l	5,0 NTU	Min. 5 gr.germane	2500 μS/cm	0,2 mg/l	0,05 mg/l	-	1,0 mg/l
177	St. Tratare Zimnicea	7,4/ 20,0°C	<0,033	<0,004	45,5	234,3	1,9	0,5	0,72	24,8	2004/20,0°C	0,139	0,031	0,05	0,55
178	Piata Zimnicea	7,5/ 20,0°C	<0,033	<0,004	48,6	241,4	1,7	0,35	0,66	26,6	2108/20,0°C	0,145	0,033	0,05	0,4
179	Sediul Apa Serv Zimnicea	7,5/ 20,0°C	<0,033	<0,004	49,1	248,5	0,9	0,45	3,73	26,6	1954/20,0°C	0,153	0,035	0,05	0,5

Intocmit,
Sef D.M.C.A.,
Chimist Georgescu Iuliana